

Mitchell, Brian

---

**From:** Wilken, Keith <keith.wilken@dnr.iowa.gov>  
**Sent:** Friday, February 01, 2019 2:26 PM  
**To:** Mitchell, Brian  
**Cc:** Jefferson Water Plant  
**Subject:** City of Jefferson CIS 1,2 Dichloroethylene  
**Attachments:** 20190201141108180.pdf

Brian,

Good afternoon. Thank you for the telephone conversation this afternoon.

I have attached an aerial photograph from Jefferson's Phase II Source Water Protection Plan. This photograph depicts the locations of the 4 town wells in Jefferson.

The most recent sampling results from the wells were on 6/7/2017.

Well #4 yielded 0.00725 mg/L  
Well #6 yielded 0.00092 mg/L  
Well #9 yielded 0.0177 mg/L  
Well #10 was <0.0005 mg/L

The most recent finished water (as the water leaves the treatment plant) sampling results are;

0.00131 mg/L on 12/4/2017  
0.00163 mg/L on 4/2/2018  
0.00147 mg/L on 10/9/2018

It would be greatly appreciated if you could keep us updated on the status of your investigation. Do not hesitate to let either myself or the City of Jefferson know if you need anything further.

Keith

----- Forwarded message -----

From: <DNRATLPRN02@iowa.gov>  
Date: Fri, Feb 1, 2019 at 2:13 PM  
Subject: Message from "DNRATLPRN02"  
To: Keith Wilken <keith.wilken@dnr.iowa.gov>



This E-mail was sent from "DNRATLPRN02" (MP C4504ex).

Scan Date: 02.01.2019 14:11:08 (-0600)

Queries to: [DNRATLPRN02@iowa.gov](mailto:DNRATLPRN02@iowa.gov)

--



**Keith Wilken** | Environmental Specialist Senior

Iowa Department of Natural Resources

P 712-243-1934 | F 712-243-6251 | 1401 Sunnyside Ln., Atlantic IA 50022

[www.iowadnr.gov](http://www.iowadnr.gov)



# Jefferson Water Department Potential Contaminant Sites

